



Dr. B. P. AGRAWAL SHIKSHA NIKETAN

.....Chariot of Knowledge

KALYANKUNJ, FATEHGARH - KANPUR ROAD

FARRUKHABAD (U.P.) - 209749

Mob.: 9565467882, 9129298033

E-mail: admin@dbpasn.com

Website: www.dbpasn.com/

दिनांक 24-09-2026

सेवा में,

श्रीमान अधिशासी अभियंता (जल निगम)
जनपद - फर्रुखाबाद

विषय - जल गुणवत्ता रिपोर्ट प्रदान करने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक अवगत कराना है कि हमारे विद्यालय डॉ. बी. पी. अग्रवाल शिक्षा निकेतन, कल्यानकुंज, कानपुर रोड, याकूतगंज, फतेहगढ़, फर्रुखाबाद में आवश्यक कार्य हेतु जल प्रमाण पत्र की आवश्यकता है।

अतः आपसे अनुरोध है कि जल गुणवत्ता रिपोर्ट निर्गत करने का कष्ट करें।

धन्यवाद !

भवदीय!

प्रधानाचार्य

PRINCIPAL

Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad

डॉ. बी. पी. अग्रवाल शिक्षा
निकेतन, कल्यानकुंज, कानपुर रोड,
याकूतगंज, फतेहगढ़, फर्रुखाबाद

C.K. Gupta

MANAGER

Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad

AE/DE (Lab)
Lab Chemist
Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad

PRINCIPAL

Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad



Water Analysis Report
District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural), Kannauj



Dr. B.P. Agrawal Shiksha Niketan
Fatehgarh, Farrukhabad

ULR No	TC-12203-25000000040F	Report No	2196	Date	18.08.2025	Page No	1
--------	-----------------------	-----------	------	------	------------	---------	---

Customer Details

Office Name & Address	Dr. B.P. Agrawal Shiksha Niketan, Kalyankunj, Kanpur Road, Yakutganj, Fatehgarh, Farrukhabad U.P.
Reference Letter Date	13.08.2025

Basic Details of the Sample

District	Farrukhabad	Block	Barhpur
Gram Panchayat	-	Village	-
Habitation	-	Location	Dr. B.P. Agrawal Shiksha Niketan, Kalyankunj, Fatehgarh
Water Source	Tubewell	Sample No.	1
Quantity of the Sample	2000ml	Date of Sample Collection	13.08.2025
Receiving Date	13.08.2025	Sample Collector	Mr. Shivendra Kumar
Sample Depositor	Mr. Shivendra Kumar	Sampling Method	IS 17614 (Part 1):2021
Analysis Start Date	14.08.2025	Analysis Completion Date	14.08.2025

Environmental Condition

Temperature	25 ⁰ C	Humidity	56%
-------------	-------------------	----------	-----

Technical Data of Analysis

S.N o	Analysed Parameter	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	A	Agreeable	Agreeable	IS:3025(Part-5):2018
2	Taste	A	Agreeable	Agreeable	IS:3025(Part-8):2023
3	pH	7.76	6.5-8.5	6.5-8.5	IS 3025(Part 11):2022 Electrometric Method
4	Turbidity(NTU)	0.46	1	5	IS 3025 (Part 10):2023
5	TDS(mg/L)	332	500	2000	IS 3025 (Part 16):2023
6	Chloride(mg/L)	34	250	1000	IS 3025(Part 32):2019
7	Total Alkalinity(mg/L)	168	200	600	IS 3025 (Part 23):2023
8	Total Hardness(mg/L)	236	200	600	IS 3025 (Part 21):2019
9	Calcium(mg/L)	57.71	75	200	IS 3025(Part 40): 2023
10	Magnesium(mg/L)	22.35	30	100	IS 3025 (Part 46):2023
11	Sulphates(mg/L)	37.49	200	400	APHA 24th Edition 4500 SO ₄ Method F, 2023
12	Nitrate(mg/L)	38.42	45	45	APHA 24th Edition Method 4500 NO ₃ ⁻ B,2023
13	Fluoride(mg/L)	0.567	1	1.5	APHA 24th Edition 4500 F Method C, 2023
14	Iron(mg/L)	0.06	0.3	1.0	APHA 24th Edition-3500-Fe Method B,2023

Note	1. This certificate refers only to the particular sample(s) submitted for testing.
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of the Laboratory.
	3. The Test results reported in this certificate are valid at the time of and under the stated conditions of Measurements.
	4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue .

Deputy Quality Manager

Authorized Signatory
Mohd. Amjad Khan
Quality Manager

Analysis Report



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Gwal Maidan, Kannauj

Report No. 2196 Date 18.08.2025 Page No. 1 page 1/1

Office Name and Address Dr. B.P. Agrawal Shiksha Niketan, Kalyankunj, Kanpur Road, Yakutganj, Fatehgarh, Farrukhabad U.P.
Ref Letter Date 13.08.2025

Basic details of sample

District Farrukhabad Block/Area Barhpur
Gram Panchayat NA Village/Ward NA
Habitation NA Location Dr. B.P. Agrawal Shiksha Niketan, Kalyankunj, Kanpur Road, Yakutganj, Fatehgarh
Water Source Tubewell Sample No. 1
Quantity of Sample 250 ml Date of S.C. 13.08.2025
Receiving Date 13.08.2025 S. Collector Mr. Shivendra Kumar
Sample Depositer Mr. Shivendra Kumar
Analysis Start Date 13.08.2025 Analysis Completion Date 14.08.2025

Environmental Condition

Temperature

37°C

Relative Humidity

58%

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Total Coliform	CFU/100 mL	0.00	0	0	IS-15185 or ISO-9308-1
2	E.coli	CFU/100 mL	0.00	0	0	IS-15185 or ISO-9308-1

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise

Data prepared by

Authorized Signatory
District Level Water Testing Laboratory
Microbiologist
* P.P.J.N. Kannauj *
Microbiologist

**End of Test Report **

C.K. Capla

MANAGER

Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad

PRINCIPAL

Dr. B.P. Agrawal Shiksha Niketan
Kalyan Kuni, Fatehgarh-Farrukhabad